

Classification Report

| | |
|------------------|--|
| Number | 18-002246-PR01 (NW-A01-02-en-02) |
| Owner | Salamander Industrie-Produkte GmbH Jakob-Sigle-Str. 58 86842 Türkheim Germany |
| Product | Fixed light with mullion |
| Designation | Shipping name: Streamline 60 |
| Details | Manufacturer Salamander, Industrie-Produkte GmbH - Türkheim; Material Polyvinyl Chloride unplasticized (PVC-U) white; Type of opening Fixed; Overall dimensions (W x H) 1400 mm x 1500 mm |
| Special features | |

Result

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: C5/B5/A5

Watertightness according to EN 12208:1999-11



Class: E1500

Basis *)

EN 14351-1:2006+A2:2016-09
*) and corresponding national versions
e.g. DIN EN)

Test report: 18-002246-PR01 PB-
A01-02-en-02

test sequence CE to EN 14351-1
Replaces ift-Nachweis:

18-002246-PR01 NW-A01-02-en-
01 dated 23.08.2018.

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim

12.09.2018



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Daniel Gromotka, B.Eng.
Operating Testing Officer
Building Component Testing

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 456-3B0E9